

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD
 (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT NANGLOI, DELHI-110041



Water sample collected from " Sant Kirpal Model School" Plot No- 72 Kh No- 154/5 Sultan Garden , Shiv Enclave, Najafgarh New Delhi -110043 vide challan No- 256 Dated-15.12.2022.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
PHYSICAL EXAMINATION					
1.	Date of collection	-----	--	--	23.12.2022
2.	Date of Analysis	-----	--	--	23.12.2022
3.	Colour	Hazen	5.0	15	Clear
4.	Odour	-----	No. Objectionable		No Obj
5.	Turbidity	N.T.U.	1.0	5.0	1.28
6.	PH value	-----	6.5	8.5	7.6
7.	Electrical Conductivity	µmho	--	--	308.9
8.	Total dissolved solids	mg/l	500	2000	200.2
CHEMICAL EXAMINATION					
9.	P th Alkalinity	mg/l	--	--	NIL
10.	Total Alkalinity	mg/l	200	600	116
11.	Total Hardness	mg/l	200	600	126
12.	Calcium Hardness	mg/l	--	--	78
13.	Magnesium Hardness	mg/l	--	--	48
14.	Calcium as Ca	mg/l	75	200	31.2
15.	Magnesium as Mg	mg/l	30	100	11.52
16.	Ammonia as N	mg/l	0.5	N.R.	NIL
17.	Nitrite as N	mg/l	---	---	NIL
18.	Nitrate as NO ₃	mg/l	45	N.R.	3.8
19.	Sulphate	mg/l	200	400	36
20.	Chloride	mg/l	250	1000	24
21.	Dissolved Iron	mg/l	0.3	N.R.	0.06
22.	Fluoride	mg/l	1	1.5	0.12
23.	Cyanide	mg/l	0.05	N.R.	ND
24.	Residual Chlorine	mg/l	0.20	1.0	0.25
BACTERIOLOGICAL EXAMINATION					
25.	Coli-form per 100 ml at 37°C	MPN	0		0

REMARKS : As per tested parameters sample -S1 can be use for drinking purpose.


Sepan Singh
 Chemist

Charmy
 Vice Principal
SANT KIRPAL MODEL SCHOOL
 (Sr. Secondary Recognised)
 Shiv Enclave, Dichaon Kalan Road,
 Najafgarh, New Delhi-110043

Jalbir
 02/10/23
ACWA
 Asst. Chief Analyst
DELHI JAL BOARD



Municipal Corporation of Delhi
Office of Deputy Health Officer
Najafgarh Zone



No: DHO/NGZ/MCD/2022/D- 3297

Dated : 04/11/2022

1. Name of the School **SANT KIRPAL MODEL SCHOOL**
2. School Address **SHIV ENCLAVE, DICHAON KALAN ROAD, NAJAFGARH NEW DELHI 110043.**
3. No. of Shift **ONE** Timing **08:00 AM TO 1:30 PM**
4. No. of Students: **Boys 328 Girls 230 Total = 558**
5. No. of Staffs: **Male 02 Female 26 Total = 28**

Details of Accommodations present in School

- | | |
|---|--|
| 1. Floor Space in the Classroom Sufficient/insufficient | SUFFICIENT |
| 2. The Classrooms are Well Lighted/ ill lighted | WELL LIGHTED |
| 3. The Classrooms are Well Ventilated/ ill ventilated | WELL VENTILATED |
| 4. The Classrooms are kept / Not kept Neat & Clean: | NEAT AND CLEAN |
| 5. The Building requires/does not required Whitewash etc. | NOT REQUIRED |
| 6. The Drinking Water is Wholesome/ not wholesome | WHOLESOME |
| 7. The Latrine arrangement is Sanitary/ insanitary | SANITARY FROM HEALTH POINT OF VIEW. |


No. of toilets seats for student

1. One latrine-cum-urinal is required for 25 female student, so total is **SUFFICIENT**
2. One latrine for 40 male student is required so total is **SUFFICIENT**
3. Separate Toilet arrangement for staff present: Yes/No **YES SEPARATE EXISTS FOR STAFF.**
4. The Overall facilities: Good/ Adequate/Inadequate **GOOD FROM HEALTH POINT OF VIEW.**

If building Department or any other govt. agency takes actions against u/a construction or any dispute, then the Health Certificate will be stand cancelled /revoked without any further intimation in this regard


Vice Principal

SANT KIRPAL MODEL SCHOOL
(Sr. Secondary Recognised)
Shiv Enclave, Dichaon Kalan Road,
Najafgarh, New Delhi 110043


Deputy Health Officer
Najafgarh Zone
Deputy Health Officer
Najafgarh Zone, MCD

Remarks: This Certificate is valid for one year from the date of issue and this has no bearing on any unauthorized construction)